



March 11, 2013

DALMARAY CONCRETE PRODUCTS, INC  
AARON AUSEN  
405 S ARCH ST  
JANESVILLE WI 53548

Re: Description: SEWAGE TREATMENT APPARATUS (see SEWAGE TANKS, STA-TIERS, ETC.)  
Manufacturer: DALMARAY CONCRETE PRODUCTS, INC  
Product Name: SEDIMENTATION TANK  
Model Number(s): 46 GAL.  
Product File No: 20130008

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2018.

This approval supersedes the approval issued on April 9, 2008 under product file number 20080194.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed downstream of adequately sized POWTS treatment tank(s).
- This product is NOT required to have a baffle installed on the inlet.
- This product must have an approved effluent filter installed on the outlet.
- Additional information is included as attachment(s) to this letter; see attachment A.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 266-2602 Fax  
glen.schlueter@wi.gov E-mail